



CITY OF PROVIDENCE, RHODE ISLAND

Department: Purchasing

**RFP Title: Re-Advertised Fire Alarm/ Extinguisher, Sprinkler Systems and Emergency Repairs
Blanket Contract FY25 One Year Contract with Three-One Year Options to Renew**

Opening Date: 07/01/2024

Addendum #: 1

Issue Date: 06/17/2024

The purpose of this addendum is:

to extend the opening date to July 1st, 2024 and to include additional services to the scope of work:

1. Fire Pump Churn Test

The City requires monthly tests for the fire pump churns that comply with the National Fire Protection Association (NFPA) codes. The selected vendor is expected to notify the Fire Department before disabling the fire alarm systems.

The City expects the selected vendor to provide a routine inspection, testing, and maintenance (ITM). The requirements for ITM of fire pumps are found in NFPA 25, Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems.

Please include a proposed procedure for the Fire Pump Churn Test. Your proposal will be compared against the standard ITM under the NFPA code.

Please specify in your proposal whether the fire pump churn service tests include any refilling of oil or fuel.

2. Fire Department Connection (FDC) Exercises

Providence City Hall
25 Dorrance Street
Providence, RI 02903



CITY OF PROVIDENCE, RHODE ISLAND

The City requires quarterly inspections of the Fire Department Connections (FDC) that comply with the National Fire Protection Association (NFPA) codes.

Please include a proposed procedure for the FCD inspections. Your proposal will be compared against the NFPA codes.